

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. DSO/26-27/0005

Dated:

It is certified that an inspection team headed by DR. RAMIT KUMAR SINGH, DSO

(Name of Officers with designation) from CMD OFFICE, BSR PHED

inspected the HAPPY BLUE BIRD PUBLIC SCHOOL, TANIPUR KALAN
LINK ROAD, SHIKARPUR, BULANDSHAHR

(Name & Address of the school) on 13/5/26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. T.9249 dated 22/04/2026

of DISTRICT LEVEL WATER ANALYSIS LAB (Lab) certified that the


HAPPY BLUE BIRD PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 12/5/27

Signature with Seal: 


Name : DR. RAMIT KUMAR SINGH

Designation : DSO

Name & Address of the Office / Department :

To
HAPPY BLUE BIRD PUBLIC SCHOOL
TANIPUR KALAN ROAD, SHIKARPUR, BSR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


PRINCIPAL
HAPPY BLUE BIRD PUBLIC SCHOOL
SHIKARPUR, BULANDSHAHR



District Level Water Analysis Laboratory UP Jal Nigam (Rural), Bulandshahr

TEST REPORT

UTR NO:	T 9249	Issue Date	22/04/2026
Sample receipt Date:	13/04/2026		
Customer/Party Name	HAPPY BLUE BIRD PUBLIC SCHOOL		
Address	JANIPUR KALA LINK ROAD SHIKARPUR BULANDSHAHR		
Contact No.	7290086265		
Date of Sampling	13/04/2026	Sample Code:	B-179
Sample Description	13/04/2026	Quantity of Sample	1000ML
Quantity	1	Water Source	WEB POOL
Packing details		Sampling Method	As per IS 17614:Part-2021
Analysis Start	15/04/2026	Analysis Completion Date	17/04/2026
Temperature	31.7°C	Humidity	59%

Water Sample Provided By Shalabh Kumar Agrawal

Availability of Equipments:		Availability of reference standards:		Adequacy of sample quantity	01
Availability of Test method:	IS 3025	Availability of Trained person:		Duration of testing/Time of Report release	12:10 pm

TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	7.995	
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	1.706	(NTU)*
3	TDS (ppm)	IS 3025 (Part 16):2017	500	2000	755.9	(Mg/L)*
4	Chloride	IS 3025 (Part 32): 2019	250	1000	130	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	416	(Mg/L)*
6	Total Hardness	IS 3025 (Part 21):2019	200	600	270	(Mg/L)*
7	Colour (Hazen)	APHA 23 rd Edition	5	15	11	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitative
9	Odour	IS 3025 (Part): 2018	Agreeable	Agreeable	Agreeable	Agreeable
10	Calcium as Ca (ppm)		75	200	122	(Mg/L)

11	Magnesium as (ppm)		30	100	68.36	(Mg/L)
12	Sulphate as SO ₄ (ppm)	APHA 24 th Edition -4500-SO ₄ Method E (Turbidimetric Method) 2023	200	400	204	(Mg/L)
13	Nitrate as NO ₃ (ppm)	APHA 24 th Edition -4500-NO ₃ Method D (UV Screening Method) 2023	45	No Relaxation	10	(Mg/L)
14	Fluoride as F (ppm)	APHA 24 th Edition - 4500 - F Method C (Electrode Method) 2017-2023	1.0	1.5	0.50	(Mg/L)
15	Iron as Fe (ppm)	APHA 24 th Edition 3500 -Fe Method B (Phenanthroline Method)	1.0	No Relaxation	0.11	(Mg/L)
Remark		"The Information regarding sample collected, submitted and Customer basic details provided by the customer itself."				

REVIEW ON ANALYSIS:-

Only basis of above parameter analysis data values for given sample within safe range and under Acceptable Limit according to BIS 10500:2012.

- PASS
- FAIL

Reviewed By

PRINCIPAL
HAPPY BLUE BIRD PUBLIC SCHOOL
SHIKARPUR, BULANDSHAHR

End of Report

Page 2 of 2

